

King Wahoo Electronics Co., Ltd
Mr. Jenb Zheng Manager
Engineer Dept.
105-4 Bri 3rd St
Keelung 20648
Taiwan

Date : 13.11.2017
Our ref. : YFC 05
Your ref.:

Ref : J Certificate of Surveyed Conformity

Type of Equipment : Sub-miniature Fuse-links
Model Designation : See Certificate
Certificate No. : J 50392871 0001
Report No. : 10025047 005

Dear Mr. Jenb Zheng,

The above specified technical equipment has been tested and found to be in accordance with the relevant requirements.

Enclosed you will find the certificate of approval.

If cancellation of the certificate is submitted by November 15 in a given year, no fee will be charged for the following year.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

Please contact our office for approval of your new products.

With kind regards,

Certification Body

G. Yin

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询

Zertifikat
mit überwachter Konformität

Certificate
of surveyed conformity



Zertifikat Nr. *Certificate No.*
J 50392871

Blatt *Page*
0001

<i>Ihr Zeichen Client Reference</i>	<i>Unser Zeichen Our Reference</i>	<i>Ausstellungsdatum Date of Issue</i>	<i>(day/mo/yr)</i>
	05-YFC-10025047 005	13.11.2017	

Genehmigungsinhaber *License Holder*

King Wahoo Electronics Co., Ltd
105-4 Bri 3rd St
Keelung 20648
Taiwan

Fertigungsstätte *Manufacturing Plant*

King Wahoo Electronics Co., Ltd
No. 23 Jintan Road
Shanwu, Shijie Town
Dongguan, GuangDong 523295
P. R. China

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*

EN 60127-1:2006+A1+A2
EN 60127-3:2015

**Zertifiziertes Produkt (Geräteidentifikation)
*Certified Product (Product Identification)***

**Lizenzentgelte - Einheit
*License Fee - Unit***

(Sub-miniature Fuse-links)

Type Designation	: KET	5
Trademark	: King Wahoo (logo)	
Rated Voltage:	Rated Breaking Capacity:	
AC 250V	35A or 10In (which is higher)	
AC 277V/300V/350V	100A	
AC 400V	50A	
DC 72V	200A	
Rated Current (In)	: 200mA; 250mA; 315mA; 400mA; 500mA; 600mA; 800mA; 1A; 1,25A; 1,6A; 2A; 2,5A; 3,15A; 4A; 5A; 6,3A	7

Time/Current Characteristic: T

Remark: The requirements of standard sheet 4 were taken into consideration.

12

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde.
Das Produkt entspricht den o.g. Anforderungen, die Herstellung wird überwacht.
This certificate is based on our Testing and Certification Regulation. The product fulfills above mentioned requirements, the production is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com

Fax: +49 221 806-3935 http://www.tuv.com/safety

